



CERTIFICATE OF ANALYSIS

Work Order Number:

16I2315

Allegany-Limestone School
Attn: Allen Backer
3131 Five Mile Road
Allegany, NY 14706

Date Reported 10/04/2016
Date Received 09/22/2016
Account Number 00000080146



Subject: Lead Project

Purchase Order: 800190

TEST	METHOD	RESULT	UNITS	PREPARED	ANALYZED	TECH	NOTES
16I2315-01 Kitch. Back Single Faucet Sink							
Sample Date/Time:	9/21/16 5:50 am	Matrix:	Drinking Water	Sampled By: Client			
Lead	SM3113 B-04	0.0326 mg/L		10/1/16 9:55	10/1/16 13:59	BJJ	X
16I2315-02 Kitch. Triple Sinks Left Faucet							
Sample Date/Time:	9/21/16 5:50 am	Matrix:	Drinking Water	Sampled By: Client			
Lead	SM3113 B-04	0.00402 mg/L		10/1/16 9:55	10/1/16 13:59	BJJ	
16I2315-03 Kitch. Triple Sink Right Faucet							
Sample Date/Time:	9/21/16 5:51 am	Matrix:	Drinking Water	Sampled By: Client			
Lead	SM3113 B-04	0.00577 mg/L		10/1/16 9:55	10/1/16 13:59	BJJ	
16I2315-04 Rm 137 Classroom Sink Faucet							
Sample Date/Time:	9/21/16 5:55 am	Matrix:	Drinking Water	Sampled By: Client			
Lead	SM3113 B-04	<0.00100 mg/L		10/1/16 9:55	10/1/16 13:59	BJJ	
16I2315-05 Rm 137 Calssroom Fountain							
Sample Date/Time:	9/21/16 5:55 am	Matrix:	Drinking Water	Sampled By: Client			
Lead	SM3113 B-04	0.0109 mg/L		10/1/16 9:55	10/1/16 13:59	BJJ	
16I2315-06 Cafe, Boys Lav. Left Sink							
Sample Date/Time:	9/21/16 6:00 am	Matrix:	Drinking Water	Sampled By: Client			

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed and is rendered upon condition that it is not to be reproduced wholly or in part for advertising or other purposes without approval from the laboratory.

NELAP accredited by PA, NY. Visit our website to view our current NELAC accreditations for various drinking water, wastewater and solid & chemical materials, air & emissions analytes



CERTIFICATE OF ANALYSIS

Work Order Number:

16I2315

Allegany-Limestone School
Attn: Allen Backer
3131 Five Mile Road
Allegany, NY 14706

Date Reported 10/04/2016
Date Received 09/22/2016
Account Number 00000080146



Subject: Lead Project

Purchase Order: 800190

TEST	METHOD	RESULT	UNITS	PREPARED	ANALYZED	TECH	NOTES
							<i>...continued</i>
16I2315-06	Cafe, Boys Lav. Left Sink						
Sample Date/Time:	9/21/16 6:00 am	Matrix:	Drinking Water	Sampled By:		Client	
Lead	SM3113 B-04	0.00384 mg/L		10/1/16 9:55	10/1/16 13:59	BJJ	
16I2315-07	Cafe Boys Lave. Right Sink						
Sample Date/Time:	9/21/16 6:00 am	Matrix:	Drinking Water	Sampled By:		Client	
Lead	SM3113 B-04	0.00412 mg/L		10/1/16 9:55	10/1/16 13:59	BJJ	
16I2315-08	Cafe Hall Right Fountain						
Sample Date/Time:	9/21/16 6:04 am	Matrix:	Drinking Water	Sampled By:		Client	
Lead	SM3113 B-04	0.00673 mg/L		10/1/16 9:55	10/1/16 13:59	BJJ	
16I2315-09	Cafe Hall Lef Fountain						
Sample Date/Time:	9/21/16 6:04 am	Matrix:	Drinking Water	Sampled By:		Client	
Lead	SM3113 B-04	0.00851 mg/L		10/1/16 9:55	10/1/16 13:59	BJJ	
16I2315-10	Cafe Girl's Right Sink						
Sample Date/Time:	9/21/16 6:06 am	Matrix:	Drinking Water	Sampled By:		Client	
Lead	SM3113 B-04	0.00727 mg/L		10/1/16 9:55	10/1/16 13:59	BJJ	
16I2315-11	Cafe Girl's Left Sink						
Sample Date/Time:	9/21/16 6:06 am	Matrix:	Drinking Water	Sampled By:		Client	
Lead	SM3113 B-04	0.00792 mg/L		10/1/16 9:55	10/1/16 13:59	BJJ	

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed and is rendered upon condition that it is not to be reproduced wholly or in part for advertising or other purposes without approval from the laboratory.

NELAP accredited by PA, NY. Visit our website to view our current NELAP accreditations for various drinking water, wastewater and solid & chemical materials, air & emissions analytes



CERTIFICATE OF ANALYSIS

Work Order Number:

16I2315

Allegheny-Limestone School
Attn: Allen Backer
3131 Five Mile Road
Allegheny, NY 14706

Date Reported 10/04/2016
Date Received 09/22/2016
Account Number 00000080146



Subject: Lead Project

Purchase Order: 800190

TEST	METHOD	RESULT	UNITS	PREPARED	ANALYZED	TECH	NOTES
							<i>...continued</i>
16I2315-11 Cafe Girl's Left Sink							
Sample Date/Time:	9/21/16 6:06 am	Matrix:	Drinking Water	Sampled By:	Client		
Lead	SM3113 B-04	0.00738 mg/L		10/1/16 9:55	10/1/16 13:59	BJJ	
16I2315-12 Rm 131 Classroom Sink Faucet							
Sample Date/Time:	9/21/16 6:06 am	Matrix:	Drinking Water	Sampled By:	Client		
Lead	SM3113 B-04	0.00738 mg/L		10/1/16 9:55	10/1/16 13:59	BJJ	
16I2315-13 Rm 131 Classroom Fountain							
Sample Date/Time:	9/21/16 6:07 am	Matrix:	Drinking Water	Sampled By:	Client		
Lead	SM3113 B-04	<0.00100 mg/L		10/1/16 9:55	10/1/16 13:59	BJJ	
16I2315-14 Rm 129 Classroom Sink Faucet							
Sample Date/Time:	9/21/16 6:09 am	Matrix:	Drinking Water	Sampled By:	Client		
Lead	SM3113 B-04	0.00481 mg/L		10/1/16 9:55	10/1/16 13:59	BJJ	
16I2315-15 Rm 129 Classroom Fountain							
Sample Date/Time:	9/21/16 6:11 am	Matrix:	Drinking Water	Sampled By:	Client		
Lead	SM3113 B-04	<0.00100 mg/L		10/1/16 9:55	10/1/16 13:59	BJJ	
16I2315-16 Rm 129 Classroom Sink Faucet							
Sample Date/Time:	9/21/16 6:14 am	Matrix:	Drinking Water	Sampled By:	Client		
Lead	SM3113 B-04	<0.00100 mg/L		10/1/16 9:55	10/1/16 13:59	BJJ	

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed and is rendered upon condition that it is not to be reproduced wholly or in part for advertising or other purposes without approval from the laboratory.

NELAP accredited by PA, NY. Visit our website to view our current NELAC accreditations for various drinking water, wastewater and solid & chemical materials, air & emissions analytes



CERTIFICATE OF ANALYSIS

Work Order Number:

16I2315

Allegany-Limestone School
Attn: Allen Backer
3131 Five Mile Road
Allegany, NY 14706

Date Reported 10/04/2016
Date Received 09/22/2016
Account Number 00000080146



Subject: Lead Project

Purchase Order: 800190

TEST	METHOD	RESULT	UNITS	PREPARED	ANALYZED	TECH	NOTES
16I2315-17 Rm 127 Classroom Fountain							
Sample Date/Time:	9/21/16 6:03 am	Matrix:	Drinking Water	Sampled By: Client			
Lead	SM3113 B-04	0.00123 mg/L		10/1/16 9:55	10/1/16 13:59	BJJ	
16I2315-18 Rm 125 Classroom Sink Faucet							
Sample Date/Time:	9/21/16 6:04 am	Matrix:	Drinking Water	Sampled By: Client			
Lead	SM3113 B-04	0.00867 mg/L		10/1/16 9:55	10/1/16 13:59	BJJ	
16I2315-19 Rm 125 Classroom Fountain							
Sample Date/Time:	9/21/16 6:05 am	Matrix:	Drinking Water	Sampled By: Client			
Lead	SM3113 B-04	0.00180 mg/L		10/1/16 9:55	10/1/16 13:59	BJJ	
16I2315-20 Rm 123/121 Classroom Sink Faucet							
Sample Date/Time:	9/21/16 6:07 am	Matrix:	Drinking Water	Sampled By: Client			
Lead	SM3113 B-04	0.00553 mg/L		10/1/16 9:55	10/1/16 13:59	BJJ	
16I2315-21 Rm 123/121 Classroom Fountain							
Sample Date/Time:	9/21/16 6:07 am	Matrix:	Drinking Water	Sampled By: Client			
Lead	SM3113 B-04	<0.00100 mg/L		10/1/16 11:49	10/1/16 15:26	BJJ	
16I2315-22 Rm 120/122 Classroom Sink Faucet							
Sample Date/Time:	9/21/16 6:09 am	Matrix:	Drinking Water	Sampled By: Client			
Lead	SM3113 B-04	0.00963 mg/L		10/1/16 11:49	10/1/16 15:26	BJJ	

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed and is rendered upon condition that it is not to be reproduced wholly or in part for advertising or other purposes without approval from the laboratory.

NELAP accredited by PA, NY. Visit our website to view our current NELAP accreditations for various drinking water, wastewater and solid & chemical materials, air & emissions analytes



CERTIFICATE OF ANALYSIS

Work Order Number:

16I2315

Allegany-Limestone School
Attn: Allen Backer
3131 Five Mile Road
Allegany, NY 14706

Date Reported 10/04/2016
Date Received 09/22/2016
Account Number 00000080146



Subject: Lead Project

Purchase Order: 800190

TEST	METHOD	RESULT	UNITS	PREPARED	ANALYZED	TECH	NOTES
							<i>...continued</i>
16I2315-22	Rm 120/122 Classroom Sink Faucet						
Sample Date/Time:	9/21/16 6:09 am	Matrix:	Drinking Water	Sampled By:	Client		
Lead	SM3113 B-04	0.00108 mg/L		10/1/16 11:49	10/1/16 15:26	BJJ	
16I2315-23	Rm 120/122 Classroom Fountain						
Sample Date/Time:	9/21/16 6:09 am	Matrix:	Drinking Water	Sampled By:	Client		
Lead	SM3113 B-04	0.00108 mg/L		10/1/16 11:49	10/1/16 15:26	BJJ	
16I2315-24	Rm 124/126 Classroom Sink Faucet						
Sample Date/Time:	9/21/16 6:10 am	Matrix:	Drinking Water	Sampled By:	Client		
Lead	SM3113 B-04	0.0163 mg/L		10/1/16 11:49	10/1/16 15:26	BJJ	X
16I2315-25	Rm 124/126 Classroom Fountain						
Sample Date/Time:	9/21/16 6:10 am	Matrix:	Drinking Water	Sampled By:	Client		
Lead	SM3113 B-04	0.00308 mg/L		10/1/16 11:49	10/1/16 15:26	BJJ	
16I2315-26	Rm 113 Classroom Left Sink						
Sample Date/Time:	9/21/16 6:13 am	Matrix:	Drinking Water	Sampled By:	Client		
Lead	SM3113 B-04	0.00428 mg/L		10/1/16 11:49	10/1/16 15:26	BJJ	
16I2315-27	Rm 113 Classroom Right Sink						
Sample Date/Time:	9/21/16 6:13 am	Matrix:	Drinking Water	Sampled By:	Client		
Lead	SM3113 B-04	0.00669 mg/L		10/1/16 11:49	10/1/16 15:26	BJJ	

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed and is rendered upon condition that it is not to be reproduced wholly or in part for advertising or other purposes without approval from the laboratory.

NELAP accredited by PA, NY. Visit our website to view our current NELAP accreditations for various drinking water, wastewater and solid & chemical materials, air & emissions analytes



CERTIFICATE OF ANALYSIS

Work Order Number:

16I2315

Allegany-Limestone School
Attn: Allen Backer
3131 Five Mile Road
Allegany, NY 14706

Date Reported 10/04/2016
Date Received 09/22/2016
Account Number 00000080146



Subject: Lead Project

Purchase Order: 800190

TEST	METHOD	RESULT	UNITS	PREPARED	ANALYZED	TECH	NOTES
16I2315-28 Rm 113/111 Classroom Sink Faucet							
Sample Date/Time:	9/21/16 6:15 am	Matrix:	Drinking Water	Sampled By: Client			
Lead	SM3113 B-04	0.00683 mg/L		10/1/16 11:49	10/1/16 15:26	BJJ	
16I2315-29 Rm 113/111 Classroom Fountain							
Sample Date/Time:	9/21/16 6:15 am	Matrix:	Drinking Water	Sampled By: Client			
Lead	SM3113 B-04	0.00267 mg/L		10/1/16 11:49	10/1/16 15:26	BJJ	
16I2315-30 Rm 109 Classroom Sink Faucet							
Sample Date/Time:	9/21/16 6:18 am	Matrix:	Drinking Water	Sampled By: Client			
Lead	SM3113 B-04	0.00297 mg/L		10/1/16 11:49	10/1/16 15:26	BJJ	
16I2315-31 Rm 109 Classroom Fountain							
Sample Date/Time:	9/21/16 6:18 am	Matrix:	Drinking Water	Sampled By: Client			
Lead	SM3113 B-04	<0.00100 mg/L		10/1/16 11:49	10/2/16 15:20	BJJ	
16I2315-32 Rm 107 Classroom Sink Faucet							
Sample Date/Time:	9/21/16 6:19 am	Matrix:	Drinking Water	Sampled By: Client			
Lead	SM3113 B-04	0.00202 mg/L		10/1/16 11:49	10/2/16 15:20	BJJ	
16I2315-33 Rm 107 Classroom Fountain							
Sample Date/Time:	9/21/16 6:04 am	Matrix:	Drinking Water	Sampled By: Client			
Lead	SM3113 B-04	<0.00100 mg/L		10/1/16 11:49	10/2/16 15:20	BJJ	

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed and is rendered upon condition that it is not to be reproduced wholly or in part for advertising or other purposes without approval from the laboratory.

NELAP accredited by PA, NY. Visit our website to view our current NELAP accreditations for various drinking water, wastewater and solid & chemical materials, air & emissions analytes



CERTIFICATE OF ANALYSIS

Work Order Number:

16I2315

Allegany-Limestone School
Attn: Allen Backer
3131 Five Mile Road
Allegany, NY 14706

Date Reported 10/04/2016
Date Received 09/22/2016
Account Number 00000080146



Subject: Lead Project

Purchase Order: 800190

TEST	METHOD	RESULT	UNITS	PREPARED	ANALYZED	TECH	NOTES
							<i>...continued</i>
16I2315-33	Rm 107 Classroom Fountain						
Sample Date/Time:	9/21/16 6:04 am	Matrix:	Drinking Water	Sampled By:	Client		
Lead	SM3113 B-04	<0.00100	mg/L	10/1/16 11:49	10/2/16 15:20	BJJ	
16I2315-34	Rm 103/101 Classroom Sink Faucet						
Sample Date/Time:	9/21/16 6:08 am	Matrix:	Drinking Water	Sampled By:	Client		
Lead	SM3113 B-04	0.00120	mg/L	10/1/16 11:49	10/2/16 15:20	BJJ	
16I2315-35	Rm 103/101 Classroom Fountain						
Sample Date/Time:	9/21/16 6:08 am	Matrix:	Drinking Water	Sampled By:	Client		
Lead	SM3113 B-04	0.00251	mg/L	10/1/16 11:49	10/2/16 15:20	BJJ	
16I2315-36	Rm 100/102 Classroom Sink Faucet						
Sample Date/Time:	9/21/16 6:11 am	Matrix:	Drinking Water	Sampled By:	Client		
Lead	SM3113 B-04	0.00113	mg/L	10/1/16 11:49	10/2/16 15:20	BJJ	
16I2315-37	Rm 100/102 Classroom Fountain						
Sample Date/Time:	9/21/16 6:11 am	Matrix:	Drinking Water	Sampled By:	Client		
Lead	SM3113 B-04	0.00310	mg/L	10/1/16 11:49	10/2/16 15:20	BJJ	
16I2315-38	UPK/K Hallway Fountain						
Sample Date/Time:	9/21/16 6:13 am	Matrix:	Drinking Water	Sampled By:	Client		
Lead	SM3113 B-04			10/1/16 11:49	10/2/16 15:20	BJJ	

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed and is rendered upon condition that it is not to be reproduced wholly or in part for advertising or other purposes without approval from the laboratory.

NELAP accredited by PA, NY. Visit our website to view our current NELAP accreditations for various drinking water, wastewater and solid & chemical materials, air & emissions analytes



CERTIFICATE OF ANALYSIS

Work Order Number:

16I2315

Allegany-Limestone School
Attn: Allen Backer
3131 Five Mile Road
Allegany, NY 14706

Date Reported 10/04/2016
Date Received 09/22/2016
Account Number 00000080146



Subject: Lead Project

Purchase Order: 800190

TEST	METHOD	RESULT	UNITS	PREPARED	ANALYZED	TECH	NOTES
16I2315-39 Rm 108 Classroom Sink Faucet							
Sample Date/Time:	9/21/16 6:15 am	Matrix:	Drinking Water	Sampled By: Client			
Lead	SM3113 B-04	0.00827 mg/L		10/1/16 11:49	10/2/16 15:20	BJJ	
16I2315-40 Rm 108 Classroom Fountain							
Sample Date/Time:	9/21/16 6:16 am	Matrix:	Drinking Water	Sampled By: Client			
Lead	SM3113 B-04	<0.00100 mg/L		10/1/16 11:49	10/2/16 15:20	BJJ	
16I2315-41 Rm 110 Classroom Sink Faucet							
Sample Date/Time:	9/21/16 6:18 am	Matrix:	Drinking Water	Sampled By: Client			
Lead	SM3113 B-04	0.00388 mg/L		10/1/16 14:08	10/1/16 23:20	BJJ	
16I2315-42 Rm 110 Classroom Fountain							
Sample Date/Time:	9/21/16 6:19 am	Matrix:	Drinking Water	Sampled By: Client			
Lead	SM3113 B-04	<0.00100 mg/L		10/1/16 14:08	10/1/16 23:20	BJJ	
16I2315-43 Girls Locker Rm Sink Faucet							
Sample Date/Time:	9/21/16 6:21 am	Matrix:	Drinking Water	Sampled By: Client			
Lead	SM3113 B-04	0.00351 mg/L		10/1/16 14:08	10/1/16 23:20	BJJ	
16I2315-44 Boys Locker Rm Sink Faucet							
Sample Date/Time:	9/21/16 6:23 am	Matrix:	Drinking Water	Sampled By: Client			
Lead	SM3113 B-04	0.00243 mg/L		10/1/16 14:08	10/1/16 23:20	BJJ	

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed and is rendered upon condition that it is not to be reproduced wholly or in part for advertising or other purposes without approval from the laboratory.

NELAP accredited by PA, NY. Visit our website to view our current NELAP accreditations for various drinking water, wastewater and solid & chemical materials, air & emissions analytes



CERTIFICATE OF ANALYSIS

Work Order Number:

16I2315

Allegany-Limestone School
Attn: Allen Backer
3131 Five Mile Road
Allegany, NY 14706

Date Reported 10/04/2016
Date Received 09/22/2016
Account Number 00000080146



Subject: Lead Project

Purchase Order: 800190

TEST	METHOD	RESULT	UNITS	PREPARED	ANALYZED	TECH	NOTES
							<i>...continued</i>
16I2315-44	Boys Locker Rm Sink Faucet						
Sample Date/Time:	9/21/16 6:23 am	Matrix:	Drinking Water	Sampled By:	Client		
Lead	SM3113 B-04	0.0198 mg/L		10/1/16 14:08	10/1/16 23:20	BJJ	X
16I2315-45	Boys Locker Rm Fountain						
Sample Date/Time:	9/21/16 6:23 am	Matrix:	Drinking Water	Sampled By:	Client		
Lead	SM3113 B-04	<0.00100 mg/L		10/1/16 14:08	10/1/16 23:20	BJJ	
16I2315-46	Main Ent. Hall Fountain Left						
Sample Date/Time:	9/21/16 6:28 am	Matrix:	Drinking Water	Sampled By:	Client		
Lead	SM3113 B-04	<0.00100 mg/L		10/1/16 14:08	10/1/16 23:20	BJJ	
16I2315-47	Main Ent. Hall Fountain Right						
Sample Date/Time:	9/21/16 6:28 am	Matrix:	Drinking Water	Sampled By:	Client		
Lead	SM3113 B-04	0.00319 mg/L		10/1/16 14:08	10/1/16 23:20	BJJ	
16I2315-48	Rm 117 Classroom Sink Faucet						
Sample Date/Time:	9/21/16 6:30 am	Matrix:	Drinking Water	Sampled By:	Client		
Lead	SM3113 B-04	0.00295 mg/L		10/1/16 14:08	10/1/16 23:20	BJJ	
16I2315-49	Rm 179 Classroom Sink Faucet						
Sample Date/Time:	9/21/16 6:31 am	Matrix:	Drinking Water	Sampled By:	Client		
Lead	SM3113 B-04	0.00478 mg/L		10/1/16 14:08	10/1/16 23:20	BJJ	

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed and is rendered upon condition that it is not to be reproduced wholly or in part for advertising or other purposes without approval from the laboratory.

NELAP accredited by PA, NY. Visit our website to view our current NELAP accreditations for various drinking water, wastewater and solid & chemical materials, air & emissions analytes



CERTIFICATE OF ANALYSIS

Work Order Number:

16I2315

Allegany-Limestone School
Attn: Allen Backer
3131 Five Mile Road
Allegany, NY 14706

Date Reported 10/04/2016
Date Received 09/22/2016
Account Number 00000080146



Subject: Lead Project

Purchase Order: 800190

TEST	METHOD	RESULT	UNITS	PREPARED	ANALYZED	TECH	NOTES
16I2315-50 Rm 205 Classroom Sink Faucet							
Sample Date/Time:	9/21/16 6:33 am	Matrix:	Drinking Water	Sampled By: Client			
Lead	SM3113 B-04	0.0226 mg/L		10/1/16 14:08	10/1/16 23:20	BJJ	X
16I2315-51 Rm 203 Classroom Sink Faucet							
Sample Date/Time:	9/21/16 6:34 am	Matrix:	Drinking Water	Sampled By: Client			
Lead	SM3113 B-04	0.00200 mg/L		10/1/16 14:08	10/1/16 23:20	BJJ	
16I2315-52 Rm 201 Classroom Sink Faucet							
Sample Date/Time:	9/21/16 6:35 am	Matrix:	Drinking Water	Sampled By: Client			
Lead	SM3113 B-04	<0.00100 mg/L		10/1/16 14:08	10/1/16 23:20	BJJ	
16I2315-53 5th Grade Hallway Fountain Left							
Sample Date/Time:	9/21/16 6:38 am	Matrix:	Drinking Water	Sampled By: Client			
Lead	SM3113 B-04	<0.00100 mg/L		10/1/16 14:08	10/1/16 23:20	BJJ	
16I2315-54 5th Grade Hallway Fountain Right							
Sample Date/Time:	9/21/16 6:38 am	Matrix:	Drinking Water	Sampled By: Client			
Lead	SM3113 B-04	0.0131 mg/L		10/1/16 14:08	10/1/16 23:20	BJJ	
16I2315-55 5th Grade Girl's Lav. Left Sink							
Sample Date/Time:	9/21/16 6:40 am	Matrix:	Drinking Water	Sampled By: Client			
Lead	SM3113 B-04	0.00320 mg/L		10/1/16 14:08	10/1/16 23:20	BJJ	

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed and is rendered upon condition that it is not to be reproduced wholly or in part for advertising or other purposes without approval from the laboratory.

NELAP accredited by PA, NY. Visit our website to view our current NELAC accreditations for various drinking water, wastewater and solid & chemical materials, air & emissions analytes



CERTIFICATE OF ANALYSIS

Work Order Number:

16I2315

Allegany-Limestone School
Attn: Allen Backer
3131 Five Mile Road
Allegany, NY 14706

Date Reported 10/04/2016
Date Received 09/22/2016
Account Number 00000080146



Subject: Lead Project

Purchase Order: 800190

TEST	METHOD	RESULT	UNITS	PREPARED	ANALYZED	TECH	NOTES
							<i>...continued</i>
16I2315-55	5th Grade Girl's Lav. Left Sink						
Sample Date/Time:	9/21/16 6:40 am	Matrix:	Drinking Water	Sampled By:	Client		
Lead	SM3113 B-04	0.00413 mg/L		10/1/16 14:08	10/1/16 23:20	BJJ	
16I2315-56	5th Grade Girl's Lav. Center Sink						
Sample Date/Time:	9/21/16 6:40 am	Matrix:	Drinking Water	Sampled By:	Client		
Lead	SM3113 B-04	0.00414 mg/L		10/1/16 14:08	10/1/16 23:20	BJJ	
16I2315-57	5th Grade Girl's Lav. Right Sink						
Sample Date/Time:	9/21/16 6:40 am	Matrix:	Drinking Water	Sampled By:	Client		
Lead	SM3113 B-04	0.00368 mg/L		10/1/16 14:08	10/1/16 23:20	BJJ	
16I2315-58	5th Grade Boys Lav. Left Sink						
Sample Date/Time:	9/21/16 6:41 am	Matrix:	Drinking Water	Sampled By:	Client		
Lead	SM3113 B-04	0.00399 mg/L		10/1/16 14:08	10/1/16 23:20	BJJ	
16I2315-59	5th Grade Boys Lav. Center Sink						
Sample Date/Time:	9/21/16 6:41 am	Matrix:	Drinking Water	Sampled By:	Client		
Lead	SM3113 B-04	0.00403 mg/L		10/1/16 14:08	10/1/16 23:20	BJJ	
16I2315-60	5th Grade Boys Lav. Right Sink						
Sample Date/Time:	9/21/16 6:41 am	Matrix:	Drinking Water	Sampled By:	Client		
Lead	SM3113 B-04	0.00403 mg/L		10/1/16 14:08	10/1/16 23:20	BJJ	

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed and is rendered upon condition that it is not to be reproduced wholly or in part for advertising or other purposes without approval from the laboratory.

NELAP accredited by PA, NY. Visit our website to view our current NELAP accreditations for various drinking water, wastewater and solid & chemical materials, air & emissions analytes



CERTIFICATE OF ANALYSIS

Work Order Number:

16I2315

Allegany-Limestone School
Attn: Allen Backer
3131 Five Mile Road
Allegany, NY 14706

Date Reported 10/04/2016
Date Received 09/22/2016
Account Number 00000080146



Subject: Lead Project

Purchase Order: 800190

TEST	METHOD	RESULT	UNITS	PREPARED	ANALYZED	TECH	NOTES
16I2315-61 Rm 199 Classroom Sink Faucet							
Sample Date/Time:	9/21/16 6:43 am	Matrix:	Drinking Water	Sampled By: Client			
Lead	SM3113 B-04	0.00338 mg/L		10/2/16 14:11	10/2/16 16:00	BJJ	
16I2315-62 Rm 197 Classroom Sink Faucet							
Sample Date/Time:	9/21/16 6:44 am	Matrix:	Drinking Water	Sampled By: Client			
Lead	SM3113 B-04	0.00193 mg/L		10/2/16 14:11	10/2/16 16:00	BJJ	
16I2315-63 Rm 195 Classroom Sink Faucet							
Sample Date/Time:	9/21/16 6:45 am	Matrix:	Drinking Water	Sampled By: Client			
Lead	SM3113 B-04	<0.00100 mg/L		10/2/16 14:11	10/2/16 16:00	BJJ	
16I2315-64 Rm 193 Classroom Sink Faucet							
Sample Date/Time:	9/21/16 6:46 am	Matrix:	Drinking Water	Sampled By: Client			
Lead	SM3113 B-04	<0.00100 mg/L		10/2/16 14:11	10/2/16 16:00	BJJ	
16I2315-65 Rm 191 Classroom Sink Faucet							
Sample Date/Time:	9/21/16 9:53 am	Matrix:	Drinking Water	Sampled By: Client			
Lead	SM3113 B-04	<0.00100 mg/L		10/2/16 14:11	10/2/16 16:00	BJJ	
16I2315-66 Rm 189 Classroom Sink Faucet							
Sample Date/Time:	9/21/16 9:52 am	Matrix:	Drinking Water	Sampled By: Client			
Lead	SM3113 B-04	0.00238 mg/L		10/2/16 14:11	10/3/16 9:00	BJJ	

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed and is rendered upon condition that it is not to be reproduced wholly or in part for advertising or other purposes without approval from the laboratory.

NELAP accredited by PA, NY. Visit our website to view our current NELAC accreditations for various drinking water, wastewater and solid & chemical materials, air & emissions analytes



CERTIFICATE OF ANALYSIS

Work Order Number:

16I2315

Allegany-Limestone School
Attn: Allen Backer
3131 Five Mile Road
Allegany, NY 14706

Date Reported 10/04/2016
Date Received 09/22/2016
Account Number 00000080146



Subject: Lead Project

Purchase Order: 800190

TEST	METHOD	RESULT	UNITS	PREPARED	ANALYZED	TECH	NOTES
							<i>...continued</i>
16I2315-66 Rm 189 Classroom Sink Faucet							
Sample Date/Time: 9/21/16 9:52 am Matrix: Drinking Water Sampled By: Client							
16I2315-67 Rm 187 Classroom Sink Faucet							
Sample Date/Time: 9/21/16 9:44 am Matrix: Drinking Water Sampled By: Client							
Lead	SM3113 B-04	0.00638	mg/L	10/2/16 14:11	10/2/16 16:00	BJJ	
16I2315-68 Rm 185 Classroom Sink Faucet							
Sample Date/Time: 9/21/16 9:48 am Matrix: Drinking Water Sampled By: Client							
Lead	SM3113 B-04	0.00272	mg/L	10/2/16 14:11	10/2/16 16:00	BJJ	
16I2315-69 Rm 183 Classroom Sink Faucet							
Sample Date/Time: 9/21/16 9:50 am Matrix: Drinking Water Sampled By: Client							
Lead	SM3113 B-04	0.00156	mg/L	10/2/16 14:11	10/2/16 16:00	BJJ	
16I2315-70 Rm 181 Classroom Sink Faucet							
Sample Date/Time: 9/21/16 9:51 am Matrix: Drinking Water Sampled By: Client							
Lead	SM3113 B-04	0.00240	mg/L	10/2/16 14:11	10/2/16 16:00	BJJ	
16I2315-71 3rd/4th Grade Hallway Fountain Left							
Sample Date/Time: 9/21/16 9:42 am Matrix: Drinking Water Sampled By: Client							
Lead	SM3113 B-04	<0.00100	mg/L	10/2/16 14:11	10/2/16 16:00	BJJ	

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed and is rendered upon condition that it is not to be reproduced wholly or in part for advertising or other purposes without approval from the laboratory.

NELAP accredited by PA, NY. Visit our website to view our current NELAC accreditations for various drinking water, wastewater and solid & chemical materials, air & emissions analytes



CERTIFICATE OF ANALYSIS

Work Order Number:

16I2315

Allegany-Limestone School
Attn: Allen Backer
3131 Five Mile Road
Allegany, NY 14706

Date Reported 10/04/2016
Date Received 09/22/2016
Account Number 00000080146



Subject: Lead Project

Purchase Order: 800190

TEST	METHOD	RESULT	UNITS	PREPARED	ANALYZED	TECH	NOTES
16I2315-72 3rd/4th Grade Hallway Fountain Right							
Sample Date/Time:	9/21/16 9:42 am	Matrix:	Drinking Water	Sampled By: Client			
Lead	SM3113 B-04	<0.00100 mg/L		10/2/16 14:11	10/2/16 16:00	BJJ	
16I2315-73 3rd/4th Grade Girl's Lav. Left Sink							
Sample Date/Time:	9/21/16 9:35 am	Matrix:	Drinking Water	Sampled By: Client			
Lead	SM3113 B-04	0.00317 mg/L		10/2/16 14:11	10/2/16 16:00	BJJ	
16I2315-74 3rd/4th Grade Girl's Lav. Center Sink							
Sample Date/Time:	9/21/16 9:35 am	Matrix:	Drinking Water	Sampled By: Client			
Lead	SM3113 B-04	0.00422 mg/L		10/2/16 14:11	10/2/16 16:00	BJJ	
16I2315-75 3rd/4th Grade Girl's Lav. Right Sink							
Sample Date/Time:	9/21/16 9:35 am	Matrix:	Drinking Water	Sampled By: Client			
Lead	SM3113 B-04	0.00306 mg/L		10/2/16 14:11	10/2/16 16:00	BJJ	
16I2315-76 3rd/4th Grade Boy's Lav. Left Sink							
Sample Date/Time:	9/21/16 9:40 am	Matrix:	Drinking Water	Sampled By: Client			
Lead	SM3113 B-04	0.00301 mg/L		10/2/16 14:11	10/2/16 16:00	BJJ	
16I2315-77 3rd/4th Grade Boy's Lav. Center Sink							
Sample Date/Time:	9/21/16 9:41 am	Matrix:	Drinking Water	Sampled By: Client			
Lead	SM3113 B-04	0.00227 mg/L		10/2/16 14:11	10/2/16 16:00	BJJ	

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed and is rendered upon condition that it is not to be reproduced wholly or in part for advertising or other purposes without approval from the laboratory.

NELAP accredited by PA, NY. Visit our website to view our current NELAP accreditations for various drinking water, wastewater and solid & chemical materials, air & emissions analytes



CERTIFICATE OF ANALYSIS

Work Order Number:

16I2315

Allegany-Limestone School
Attn: Allen Backer
3131 Five Mile Road
Allegany, NY 14706

Date Reported 10/04/2016
Date Received 09/22/2016
Account Number 00000080146



Subject: Lead Project

Purchase Order: 800190

TEST	METHOD	RESULT	UNITS	PREPARED	ANALYZED	TECH	NOTES
16I2315-77 3rd/4th Grade Boy's Lav. Center Sink							<i>...continued</i>
Sample Date/Time:	9/21/16 9:41 am	Matrix:	Drinking Water	Sampled By:	Client		
Lead	SM3113 B-04	0.00272 mg/L		10/2/16 14:11	10/2/16 16:00	BJJ	
16I2315-78 3rd/4th Grade Boy's Lav. Right Sink							
Sample Date/Time:	9/21/16 9:42 am	Matrix:	Drinking Water	Sampled By:	Client		
Lead	SM3113 B-04	0.00272 mg/L		10/2/16 14:11	10/2/16 16:00	BJJ	
16I2315-79 Rm 178 Classroom Sink Faucet							
Sample Date/Time:	9/21/16 6:34 am	Matrix:	Drinking Water	Sampled By:	Client		
Lead	SM3113 B-04	0.00471 mg/L		10/2/16 14:11	10/2/16 16:00	BJJ	
16I2315-80 Rm 165 Nurses Office Sink							
Sample Date/Time:	9/21/16 6:33 am	Matrix:	Drinking Water	Sampled By:	Client		
Lead	SM3113 B-04	0.00472 mg/L		10/2/16 14:11	10/2/16 16:00	BJJ	
16I2315-81 Rm 165 Nurses Bathroom Lav. Sink							
Sample Date/Time:	9/21/16 6:22 am	Matrix:	Drinking Water	Sampled By:	Client		
Lead	SM3113 B-04	0.00484 mg/L		10/2/16 14:39	10/2/16 19:21	BJJ	
16I2315-82 Rm 163 Art Room Sink Left							
Sample Date/Time:	9/21/16 6:21 am	Matrix:	Drinking Water	Sampled By:	Client		
Lead	SM3113 B-04	0.00737 mg/L		10/2/16 14:39	10/2/16 19:21	BJJ	

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed and is rendered upon condition that it is not to be reproduced wholly or in part for advertising or other purposes without approval from the laboratory.

NELAP accredited by PA, NY. Visit our website to view our current NELAC accreditations for various drinking water, wastewater and solid & chemical materials, air & emissions analytes



CERTIFICATE OF ANALYSIS

Work Order Number:

16I2315

Allegany-Limestone School
Attn: Allen Backer
3131 Five Mile Road
Allegany, NY 14706

Date Reported 10/04/2016
Date Received 09/22/2016
Account Number 00000080146



Subject: Lead Project

Purchase Order: 800190

TEST	METHOD	RESULT	UNITS	PREPARED	ANALYZED	TECH	NOTES
16I2315-83 Rm 163 Art Room Sink Right							
Sample Date/Time:	9/21/16 6:21 am	Matrix:	Drinking Water	Sampled By: Client			
Lead	SM3113 B-04	0.00684 mg/L		10/2/16 14:39	10/2/16 19:21	BJJ	
16I2315-84 Rm 164 Spec. Ed. Room Sink							
Sample Date/Time:	9/21/16 6:23 am	Matrix:	Drinking Water	Sampled By: Client			
Lead	SM3113 B-04	0.00893 mg/L		10/2/16 14:39	10/2/16 19:21	BJJ	
16I2315-85 Kitchen/Cafe Serving Line Sink							
Sample Date/Time:	9/21/16 6:18 am	Matrix:	Drinking Water	Sampled By: Client			
Lead	SM3113 B-04	0.00450 mg/L		10/2/16 14:39	10/3/16 19:30	BJJ	

All samples received in proper condition and results conform to ISO 17025 unless otherwise noted

Some or all of the samples were collected by the customer. The verifiability of the final results are therefore limited by the customer's reported values. Microbac Laboratories, Inc. assumes that all sampling instructions are followed, and the data upon which these final results are based, have been accurately supplied by the client.

Notes and Definitions

X Exceeds regulatory limit.

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed and is rendered upon condition that it is not to be reproduced wholly or in part for advertising or other purposes without approval from the laboratory.

NELAP accredited by PA, NY. Visit our website to view our current NELAC accreditations for various drinking water, wastewater and solid & chemical materials, air & emissions analytes



CERTIFICATE OF ANALYSIS

Work Order Number:

16I2315

Allegany-Limestone School
Attn: Allen Backer
3131 Five Mile Road
Allegany, NY 14706

Date Reported 10/04/2016
Date Received 09/22/2016
Account Number 00000080146



Subject: Lead Project

Purchase Order: 800190

TEST	METHOD	RESULT	UNITS	PREPARED	ANALYZED	TECH	NOTES
mg/kg	= Milligram per Kilogram (ppm)	Negative/Absent					= Bacteria or target analyte not detected
ug/L	= Micrograms per Liter (ppb)	CFU					= Colony Forming Unit
ug/kg	= Micrograms per Kilogram (ppb)	ND					= Not detected at or below the reporting limit
mg/L	= Milligrams per Liter (ppm)	TIC					= Tentatively Identified Compound
1000 ug	= 1 mg	"<"					= Less than (also see "ND")
Positive/Present	= Bacteria or target analyte detected	">"					= Greater than
HSCC	= High Sensitivity Coliform Count	MPN					= Most Probable Number

An E associated with Microbiology values designates that the result obtained was outside of the method specified counting range. Estimated counts are valid, but must be notated as such per regulation.

Project Requested Certification(s):

Certificate ID	Agency
NY DOH# 10121	New York State Department of Health

Sub-Contract Laboratories:

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed and is rendered upon condition that it is not to be reproduced wholly or in part for advertising or other purposes without approval from the laboratory.

NELAP accredited by PA, NY. Visit our website to view our current NELAC accreditations for various drinking water, wastewater and solid & chemical materials, air & emissions analytes



CERTIFICATE OF ANALYSIS

Work Order Number:

16I2315

Allegany-Limestone School
Attn: Allen Backer
3131 Five Mile Road
Allegany, NY 14706

Date Reported 10/04/2016
Date Received 09/22/2016
Account Number 00000080146



Subject: Lead Project
Purchase Order: 800190

TEST	METHOD	RESULT	UNITS	PREPARED	ANALYZED	TECH	NOTES
------	--------	--------	-------	----------	----------	------	-------

Reviewed and Approved By:

Date Reviewed and Approved:

10/04/2016

Carolyn Vollentine
Project Manager, Microbac Laboratories, Inc. - Erie
Report released by Carolyn Vollentine

Any questions regarding this report, please contact your account manager, .

As Regulatory limits frequently change, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits with the appropriate Federal, state or local authorities before acting on the data provided. For feedback concerning our services, please contact the Managing Director, or J. Trevor Boyce, President, at president@microbac.com.

The data and information on this, and other accompanying documents, represent only the sample(s) analyzed and is rendered upon condition that it is not to be reproduced wholly or in part for advertising or other purposes without approval from the laboratory.

NELAP accredited by PA, NY. Visit our website to view our current NELAC accreditations for various drinking water, wastewater and solid & chemical materials, air & emissions analytes

Microbac Erie Division 814.825.8533
1962 Wager Road, Erie, PA 16509

eriemm@microbac.com

Page 2 of 6



Client /Company Name: Allegany-Limestone School District								Contact Name: Alan Backer Allen Backer							
Address: 3131 Five Mile Road								Phone & Email/Fax: 716-375-6600 x2082							
City/State/Zip: Allegany, NY 14706								Bill To/PO#:							
Project Name/ID: Elementary School Lead								Disposal: Dispose of <input type="checkbox"/> Return <input type="checkbox"/> Retain <input type="checkbox"/>							
Sampled By: <i>Allen Backer</i>				Due Date:				Compliance Sample: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>				State: NY			
Type Code: G-Grab C-Composite		Comp. Start:				Comp. Stop:				Preservatives					
Matrix Code: DW-Potable water WW-Nonpotable water SS-Soil/Sludge S-Swab O-Other												LEAD by SM 3113 B			
Sample Identification	Date Taken	Time Taken	Type		Matrix	#	None	HNO3	H2SO4	NaOH	HCl			Thio	Other
			G	C											
1 Rm 127 classrm fountain	9-21-16	6:03 AM	G		DW	1	X							X	
2 Rm 125 classrm Sink faucet	9-21-16	6:04 AM	G		DW	1	X							X	
3 Rm 125 classrm fountain	9-21-16	6:05 AM	G		DW	1	X							X	
4 Rm 123/121 classrm Sink faucet	9-21-16	6:07 AM	G		DW	1	X							X	
5 Rm 123/121 classrm fountain	9-21-16	6:07 AM	G		DW	1	X							X	
6 Rm 120/122 classrm Sink faucet	9-21-16	6:09 AM	G		DW	1	X							X	
7 Rm 120/122 classrm fountain	9-21-16	6:09 AM	G		DW	1	X							X	
8 Rm 124/126 classrm Sink faucet	9-21-16	6:10 AM	G		DW	1	X							X	
9 Rm 124/126 classrm fountain	9-21-16	6:10 AM	G		DW	1	X							X	
10 Rm 113 classrm Left Sink	9-21-16	6:13 AM	G		DW	1	X							X	
11 Rm 113 classrm Right Sink	9-21-16	6:13 AM	G		DW	1	X							X	
12 Rm 113/111 classrm Sink faucet	9-21-16	6:15 AM	G		DW	1	X							X	
13 Rm 113/111 classrm fountain	9-21-16	6:15 AM	G		DW	1	X							X	
14 Rm 109 classrm Sink Faucet	9-21-16	6:18 AM	G		DW	1	X							X	
15 Rm 109 classrm fountain	9-21-16	6:18 AM	G		DW	1	X							X	
16 Rm 107 classrm Sink faucet	9-21-16	6:19 AM	G		DW	1	X							X	
Relinquished By: <i>Allen Backer</i>				Date/Time: <i>10:15 AM, 9-22-16</i>				Received By: <i>Jim Daybert</i>				Date/Time: <i>9/22/16 1615</i>			
Relinquished By: <i>Jim Daybert</i>				Date/Time: <i>9/22/16 1300</i>				Received By: <i>Stefan Still</i>				Date/Time: <i>9-22-16 1300</i>			
Relinquished By: <i>Stefan Still</i>				Date/Time: <i>9-22-16 1430</i>				Received By: <i>John...</i>				Date/Time: <i>9-22-16 1430</i>			



CHAIN OF CUSTODY

Put bar code here

Microbac Erie Division 814.825.8533
1962 Wager Road, Erie, PA 16509

Page 5 of 6

eriemm@microbac.com

1612315 Allegany-Limestone School



Client /Company Name: Allegany-Limestone School District		Contact Name: Alan Backert Allen Backer	
Address: 3131 Five Mile Road		Phone & Email/Fax: 716-375-6600 x2082	
City/State/Zip: Allegany, NY 14706		Bill To/PO#:	
Project Name/ID: Elementary School Lead		Disposal: Dispose of <input type="checkbox"/> Return <input type="checkbox"/> Retain <input type="checkbox"/>	
Sampled By: <i>Michael J. Reff</i>	Due Date:	Compliance Sample: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	State: NY
Type Code: G-Grab C-Composite	Comp. Start:	Comp. Stop:	Preservatives

	Sample Identification	Date Taken	Time Taken	Type		Matrix	#	None	HNO3	H2SO4	NaOH	HCl	Thio	Other	LEAD by SM 3113 B
				G	C										
1	Rm 191 classrm Sink Faucet	9-21-16	9:53A	G		DW	1	X							X
2	Rm 189 classrm Sink Faucet	9-21-16	9:52A	G		DW	1	X							X
3	Rm 187 classrm Sink Faucet	9-21-16	9:44A	G		DW	1	X							X
4	Rm 185 classrm Sink Faucet	9-21-16	9:48A	G		DW	1	X							X
5	Rm 183 classrm Sink Faucet	9-21-16	9:50A	G		DW	1	X							X
6	Rm 181 classrm Sink Faucet	9-21-16	9:57A	G		DW	1	X							X
7	3 rd /4 th Grade Hallway Fountain Left	9-21-16	9:42A	G		DW	1	X							X
8	3 rd /4 th Grade Hallway Fountain R	9-21-16	9:42A	G		DW	1	X							X
9	3 rd /4 th Gr. Girls Lav. Left Sink	9-21-16	9:35A	G		DW	1	X							X
10	3 rd /4 th Gr. Girls Lav. Center Sink	9-21-16	9:35A	G		DW	1	X							X
11	3 rd /4 th Gr. Girls Lav. Right Sink	9-21-16	9:35A	G		DW	1	X							X
12	3 rd /4 th Gr. Boys Lav. Left Sink	9-21-16	9:40A	G		DW	1	X							X
13	3 rd /4 th Gr. Boys Lav. Center Sink	9-21-16	9:41A	G		DW	1	X							X
14	3 rd /4 th Gr. Boys Lav. Right Sink	9-21-16	9:42A	G		DW	1	X							X
15	Rm 178 classrm Sink Faucet	9-21-16	6:34A	G		DW	1	X							X
16	Rm 165 Nurses Office Sink	9-21-16	6:33A	G		DW	1	X							X

Relinquished By: <i>Allen Backer</i>	Date/Time: 10:16 AM 9-22-16	Received By: <i>Jim Dayton</i>	Date/Time: 9/22/16 10:15	Temp: 20.5 °C
Relinquished By: <i>Jim Dayton</i>	Date/Time: 9/22/16 1300	Received By: <i>Steph Shih</i>	Date/Time: 9-22-16 1300	Iced: <input checked="" type="checkbox"/> N
Relinquished By: <i>Steph Shih</i>	Date/Time: 9-22-16 1430	Received By: <i>[Signature]</i>	Date/Time: 9-22-16 1430	Intact: <input checked="" type="checkbox"/> N




CHAIN OF CUSTODY

1612315 Allegany-Limestone School

Microbac Erie Division 814.825.8533
1962 Wager Road, Erie, PA 16509

Page 6 of 6

eriemm@microbac.com



Form containing client information (Allegany-Limestone School District), contact details (Alan Backer), project name (Elementary School Lead), and a large table for sample tracking with columns for Date Taken, Time Taken, Matrix, and various chemical tests.