

1.2 Executive Summary of Sampling and Analysis:

Summary of Samples Collected at the Elementary School:

Building Name	Date of Sampling	Total Samples	At or Below Action Level*	Above Action Level*
Elementary School	October 8, 2024	91	72	19

*NYS Action Level is 5 parts per billion

Listing of Outlets Requiring Remediation

The following outlets were analyzed above the NYS Action Level:

Sample #	Location	Fixture/Outlet Type	Laboratory Analysis (in ppb)
115.2-09	Room 109	Sink	12.6
115.2-22	Room 124/126	Sink	9.5
115.2-23	Room 125	Sink	24.8
115.2-24	Room 127	Sink	17.5
115.2-25	Room 129	Sink	6.0
115.2-26	Room 131	Sink	8.8
115.2-33	Room 137	Sink	9.8
115.2-34	Kitchen Serving Handwash	Sink	11.4
115.2-41	Kitchen Dish Sprayer	Sink	5.6
115.2-43	Room 163 Left	Sink	6.0
115.2-44	Room 163 Right	Sink	41.5
115.2-54	Room 177	Sink	5.5
115.2-56	Room 178	Sink	11.1
115.2-61	Single Lav 5 Mile Road	Sink	8.6
115.2-69	Room 201	Sink	15.6
115.2-76	Room 189	Sink	6.9
115.2-78	Room 185	Sink	18.7
115.2-79	Boys Lav Maple Avenue Left	Sink	6.3
115.2-90	Room 181	Sink	5.1

1.2 Executive Summary of Sampling and Analysis:

Summary of Samples Collected at the Middle-High School:

Building Name	Date of Sampling	Total Samples	At or Below Action Level*	Above Action Level*
Middle-High School	October 8, 2024 and October 9, 2024	129	127	2

**NYS Action Level is 5 parts per billion*

Listing of Outlets Requiring Remediation

The following outlets were analyzed above the NYS Action Level:

Sample #	Location	Fixture/Outlet Type	Laboratory Analysis (in ppb)
115.1-16	Teacher Room for Science Rooms 261 and 265	Sink	5.1
115.1-113	Kitchen Nozzle Left of 2 Bay North End	Sink	5.9